

Government of Bihar
Public Health Division Madhubani
Water Quality Testing Report

District- Madhubani				Testing date - 13.10.2025													Received Sample on date - 13.10.2025	
SL. No.	Block	Location of Source	Type of Source	Parameters tested													Sample Collected by : School Staff	
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.		
1	MADHWAPUR	M. G. M. SR. SECONDARY SCHOOL, SAHARGHAT	Boring water	7.8	2.1	188	46.5	16.6	35	304	0.18	3.20	8	0.74	-	< 1.1		
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-		
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-		

Memo No. - 513

Madhubani, Dated -

13/10/2025

Copy to Principal M. G. M. Sr. Secondary School, Saharghat, Madhubani to inform regarding reference to his letter No. - MGM/39/2025

Dated :- 12/10/2025


Lab Assistant


Chemist


Executive Engineer
P.H. Division, Madhubani
EXECUTIVE ENGINEER
PH DIVISION
MADHUBANI BIHAR